



9 February 2024

(24-1101)

Page: 1/2

Committee on Technical Barriers to Trade

Original: English

NOTIFICATION

The following notification is being circulated in accordance with Article 10.6

1.	Notifying Member: <u>EGYPT</u> If applicable, name of local government involved (Article 3.2 and 7.2):
2.	Agency responsible: Egyptian Organization for Standardization and Quality 16 Tadreeb El-Modarrebeen St., Ameriya, Cairo – Egypt E-mail: eos@idsc.net.eg / eos.tbt@eos.org.eg Website: http://www.eos.org.eg Tel.: + (202) 22845528 Fax: + (202) 22845504 Name and address (including telephone and fax numbers, email and website addresses, if available) of agency or authority designated to handle comments regarding the notification shall be indicated if different from above:
3.	Notified under Article 2.9.2 [X], 2.10.1 [], 5.6.2 [], 5.7.1 [], 3.2 [], 7.2 [], other:
4.	Products covered (HS or CCCN where applicable, otherwise national tariff heading. ICS numbers may be provided in addition, where applicable): Ventilators. Fans. Air-conditioners (ICS code(s): 23.120); Heat pumps (ICS code(s): 27.080)
5.	Title, number of pages and language(s) of the notified document: Draft of the Egyptian standard "Multiple split-system air conditioners and air-to-air heat pumps — Testing and rating for performance "; (102 page(s), in English)
6.	Description of content: This draft of Egyptian standard specifies the performance testing, the standard conditions and the test methods for determining the capacity and efficiency ratings of air-cooled air conditioners and air-to-air heat pumps. It is applicable to the following equipment: Basic multi-split systems, modular multi-split systems and modular heat recovery multi-split systems. These multi-split systems include air-to-air systems with non-ducted and/or ducted indoor units with integral fans and indoor units supplied without fans. It is limited to: - Residential, commercial and industrial split-system air conditioners and heat pumps; - Factory-made, electrically driven and use mechanical compression; - Single- and multiple-circuit split-systems which utilize one or more compressors with no more than two steps of control of the outdoor unit; or - Split-systems with a single refrigeration circuit which utilize one or more variable-speed compressors or alternative compressor combinations for varying the capacity of the system by three or more steps.

	Worth mentioning is that this Draft standard adopts the technical content of ISO 15042:2017/AMD 1:2020
7.	Objective and rationale, including the nature of urgent problems where applicable: Safety requirements.; Quality requirements
8.	Relevant documents: ISO 15042:2017/AMD 1:2020
9.	Proposed date of adoption: To be determined Proposed date of entry into force: To be determined
10.	Final date for comments: 60 days from notification
11.	Texts available from: National enquiry point [X] or address, telephone and fax numbers and email and website addresses, if available, of other body: Egyptian Organization for Standardization and Quality Address: 16 Tadreeb El-Modarrebeen St., Ameriya, Cairo- Egypt E-mail: eos@idsc.net.eg / eos.tbt@eos.org.eg Website: http://www.eos.org.eg Tel: + (202) 22845528 Fax: + (202) 22845504